

Informal IFB
Unsealed Bid
For demolition of structure at
170 Castleman Road, Berryville Va.
Issued December 6, 2024

Addendum 1 Answers to Question
Issued 12/31/24

Question

May red clay be substituted for shale for the fill to be placed in the building foundation?

Answer

It is acceptable to the Town for red clay fill to be substituted for shale fill; provided that the clay is compacted to at least 95% density, capped with at least 1" of top soil, and stabilized as required in the IFB for disturbed areas.